

SHEPHERD ENGINEERING, INC.

1308 GRAFTON STREET • WORCESTER, MA 01604 • (508) 757 7793 • FAX: (508) 753 2309

MEMORANDUM

Date: December 21, 2018

To: Mr. Stephen Jablonski
Jablonski DeVriese Architects

From: John D. Shepherd

Re: 77 Maple Street
Springfield, MA

Response to RFI Electrical Questions

Drawings E1.1, E2.1, E3.1, E4.1

1. Single or double throw motor disconnect switches are acceptable for the indoor HVAC units.
2. The building owner will be responsible to furnish and install the WAPS, cabling, patch cords, servers, switches, etc. This contractor will be responsible structured pathways with pull strings as noted on the drawings.

Drawing E2.1

1. Change the fixture type "A6", to be type "A8". Typical for all "A6" fixtures.

Drawing E5.1

1. Change the fixture type A4 model number to be SPN1435KCAADU(DLC). Equal manufacturers are Philips Lighting and Ledalite.
2. Change the fixture type A4 model number to be SPN1835KCAADU(DLC). Equal manufacturers are Philips Lighting and Ledalite.

Drawing FA.1

1. Refer to the attached fire alarm plan for the proposed fire alarm system throughout the building.

General Note:

1. All exposed cabling within the finished areas be in either Wiremold or minimum of 1" conduit.